

42" MINIMUM GUARDRAIL HEIGHT AT LANDINGS  
 FOR GUARDRAIL EXCEPTIONS SEE UBC 1711  
 [\* 36" AT PRIVATE STAIR]

4" MAXIMUM CLEARANCE BETWEEN INTERMEDIATE RAILS

6'-8" MINIMUM HEADROOM  
 (PLUMB TO DIAGONAL)

AT LEAST ONE HANDRAIL SHALL EXTEND 6" BEYOND TOP AND BOTTOM RISERS EXCEPT AT PRIVATE STAIRS.

34" TO 38" HANDRAIL HEIGHT ABOVE STAIR NOSING

42"\*

4"

6'-8"

34" TO 38"

4"

TURN THIS PAGE OVER FOR:  
 LANDING LENGTH 3306(g)  
 STAIR WIDTH 3306(b)

7" MAXIMUM RISER HEIGHT  
 [\*\*8" AT PRIVATE STAIR]

ADDITIONAL NOTES

- A) THESE REQUIREMENTS APPLY [\*\*\*9" AT PRIVATE STAIR] TO STAIRWAYS WITH TWO OR MORE RISERS PER UBC 3306(o)
- B) THE GREATEST RISER HEIGHT OR TREAD WIDTH SHALL NOT EXCEED THE SMALLEST OF SAME BY MORE THAN 3/8".
- C) SEE ACCESSIBILITY STANDARDS FOR HANDICAP STAIRS.
- D) TURN THIS PAGE OVER FOR MORE INFORMATION ON STAIRS & HANDRAILS.

11" MINIMUM TREAD WIDTH (NOSE TO NOSE)  
 [\*\*\*9" AT PRIVATE STAIR]

7"\*\*\*

11"\*\*\*